



CHEROKEE COUNTY BOARD OF COMMISSIONERS
Purchasing Department
1130 Bluffs Pkwy, Canton, GA 30114
Ph: 678-493-6000 | Fax: 678-493-6035

ADDENDUM # 3

Solicitation Number: 2023-019
Solicitation Name: East Cherokee Drive and State Route 140 Intersection
Stone Façade for Concrete Walls
Addendum Release Date: April 7, 2023

Prime Bidders/Proposers acknowledge the receipt of this Addendum by inserting the number and date in the appropriate position on the Proposal Form. Failure to do so may subject the Bidder/Proposer to disqualification. This Addendum is a part of the Contract Documents. It modifies them as follows:

1. Would there be any area near the project that the city or county owns that we could use as a staging area for material?
Answer: There is no place near.
2. Will the paint and anti-graffiti coating be required to be removed on the face of the walls?
Answer: Yes. The stone installation on the face will require anchoring into the actual wall therefore removing the paint/anti-graffiti coating would not be necessary on the face. We would have to remove the paint/ anti-graffiti coating on the top to have a good bonding surface for the mortar and stone. **That is our understanding.**
3. Per GDOT Spec, the stone shall be 6in thick by 1 ft wide. Is this the dimension you are looking for?
Answer: 12" wide by 6" tall by 1" thick sounds like good dimensions.
4. Is there a specific stone design/stone quality the county is wanting for the stone façade?
Answer: No specific design or color is desired but, I would say something in the earth tone colors will be preferred and of course we want good quality whether it's granite or something else. There are many options that vary from granite to even synthetic. **We will require the awarded contractor to submit samples for approval before beginning the job.**

****END****